



San Francisco Bay Regional Water Quality Control Board

October 25, 2023

Livermore-Amador Valley Water Management Agency (LAVWMA) Chuck Weir, General Manager (<u>weir@lavwma.com</u>) 7176 Johnson Drive Pleasanton, CA 94588

Subject: Report of Inspection, LAVWMA Export and Storage Facility, Order R2-2021-0007 (NPDES Permit CA0038679), Pleasanton, Alameda County

Dear Chuck Weir:

On September 29, 2023, Regional Water Board staff conducted a compliance evaluation inspection at the LAVWMA Export and Storage Facility. The details of the inspection are included in the attached report. If you have any questions concerning this report, please contact me at <u>Natlie.Lee@waterboards.ca.gov</u>.

Sincerely,

Natlie Lee Environmental Scientist

Michael Weiss, U.S. EPA, <u>Weiss.Michael@epa.gov</u>
 Virgil Sevilla, Dublin San Ramon Services District, <u>sevilla@dsrsd.com</u>
 Jackie Zipkin, EBDA, <u>izipkin@ebda.org</u>
 DJ Alejandro, SF Bay Regional Water Board, <u>dandre.alejandro@waterboards.ca.gov</u>

Attachment: NPDES Compliance Evaluation Inspection Report - LAVWMA

CW-236689

CIWQS Inspection ID: 52985752 Entered by: NL

JAYNE BATTEY, CHAIR | EILEEN M. WHITE, EXECUTIVE OFFICER

NPDES Compliance Evaluation Inspection (CEI) Report

Facility Name and Location					ry Date	Entry Time	
Livermore-Amador Valley Water Management Agency (LAVWMA) Export and					/29/23	12:00pm	
Storage Facilities					ermit	Permit	
7176 Johnson Drive				Effect	tive Date	Expiration Date	
Pleasanton, CA 94588				7/0	1/2021	6/30/2026	
Mailing Address	Same as facility location?		Yes 🗆 No 🗵	Notifi	ed?	Yes 🛛 No 🗆	
Dublin San Ramon Servi	ces District			lf no,	rationale:		
7051 Dublin Blvd.							
CIN/OS Inspection ID	E209E7E2		Bacaiving Water	Jamo	Lowers	an Francisco Pay	
	52985752		Receiving water i	vame	Lowers	an Francisco Bay	
NPDES Permit	CA0038679		County			Alameda	
Order Number	P2 2021 0007		Plant Classificatio	<u> </u>		ΡΟΤΙΜ	
	R2-2021-0007			n		226680	
Nomes and Titles of C			CIWQS Place ID			230089	
Names and Titles of C		Dh		Email			
Name Charles Main	Title			Email			
	General Manager	51	0-410-5923	weir@lavwma.com			
lacqueline Zinkin	EBDA General Manager	51	0-278-5910	izinkin	·		
Name and Title of Rev	sponsible Official	51	.0 270 3310		ecoud.org	L	
Name	Charles Weir						
Title	LAVWMA General Manager						
Phone	(510) 410-5923						
Fmail	weir@lavwma.com						
Does responsible offic	ial match permit-based cor	ntac	t information on fil	e?		Yes 🗵 No 🗆	
Does grade level com	ply with plant classification	?				Yes 🛛 No 🗆	
Inspector Information	n i		Presented Creden	itials?		Yes 🗆 No 🖂	
Organization	San Francisco Bay Regional V	Vate	er Quality Control Boa	ard			
Name	Natlie Lee						
Title	Environmental Scientist						
Phone	(510) 622-2325						
Email	Natlie.Lee@waterboards.ca.	gov					
Organization	San Francisco Bay Regional V	Vate	er Quality Control Bo	ard			
Name	DJ Alejandro	· acc	a quanty control Dot				
Title	Scientific Aid						
Phone	(510) 622-2308						
Email	mail Dandre.Alejandro@waterboards.ca.gov						

I. PRE-INSPECTION PERMIT REVIEW

	Yes	No	N/A	
Is the facility as described in the permit?	\boxtimes			
Has the Water Board been notified of any process/production modifications?	\boxtimes			
Was a permit reissuance application submitted to the Water Board on time?			\boxtimes	
Was the permit modified prior to any facility or discharge changes?			\boxtimes	
Discharge Points				

The LAVWMA Export and Storage Facilities discharge secondary treated wastewater through the EBDA Common Outfall (Discharge Point 001 in the Dublin San Ramon Services District's NPDES permit, NPDES CA0037613) to Lower San Francisco Bay.

Facility Class	V					
Chief Plant Operator	Virgil Sevilla	Grade		V		
Peak Design Flow	 41.2 million gallons per day (MGD) – total capacity 19.7 MGD – firm capacity 21.5 MGD – interruptible capacity 					
		Yes	No	N/A		
Are current loads less	than 80% of design loads?			\boxtimes		
If no, does annual report describe timing of next plant expansion?				\boxtimes		
Pre-inspection concerns that might affect inspection process						
None.						

II. PRE-INSPECTION MONITORING REPORT REVIEW

Summary of effluent limit violations since last inspection					
			No		
	No. of		action		
Constituent	Violations	Corrective Action Reported	reported		
Chlorine, Total Residual	1	Violation occurred on March 9, 2023. The chlorine limit is 0.0 mg/L, and reported value was 0.7 mg/L. Operational staff created a standard process to perform weekly calcium thiosulfate delivery system testing and flushing and updated the flow totalizers to provide real-time data.			

Summary of receiving water violations since last inspection				
			I	No
	No	o. of	ac	tion
Parameter	Viola	ations	rep	orted
Dissolved oxygen	No	one		
Turbidity	No	one		
рН	No	one		
Temperature	No	one		
Aesthetic issues (e.g., excessive algae, bottom deposits, etc.)	No	one		
Corrective Actions Reported				
Not applicable.				
Menitoring and Departing Dreason violations since last inspection				
Nonitoring and Reporting Program violations since last inspection		Voc	No	NI / A
Responsible person signs and certifies the DMRs and/or SMRs				
Discharger monitors at frequency required by permit				
All data collected are summarized				
Coliform concentrations are calculated as required by normit (modian, mean				
etc.)		\boxtimes		
Detection limits are reported				
"Less than" and estimated values are properly carried through the calculation	ıs			
Flow measurement period used for load calculations brackets sampling perio	d			
Loading rates are properly calculated	u			
Data reported in time frame and frequency required by permit				
Have any spills/hypasses been reported to the Regional Board?				
Dates and times of snills/bypasses				
N/A				

III. RECORDS AND REPORTS REVIEW

	Requore	uired ite?	Available onsite?				
					•	Not	
	Yes	No	Yes	No	N/A	Inspected	Comments
Current NPDES permit	\boxtimes		\boxtimes				
Permit modifications	\boxtimes				\mathbf{X}		
Permit amendments	\boxtimes				\boxtimes		
Compliance orders	\boxtimes				\boxtimes		
Monitoring and reporting program	\boxtimes		\boxtimes				
Standard provisions	\boxtimes		\boxtimes				
Industrial pretreatment program						\boxtimes	
Maintenance records and log book	\boxtimes					\boxtimes	
Plant operation and	\boxtimes		\boxtimes				Online
Plant angineering drawings							
Collection system drawings							
Maintenance records							
Spill and hypass records							
Biosolids disposal plan							
Biosolid farm map and							
disposal agreements						\boxtimes	
Soil nutrient analyses						\boxtimes	
Biosolids loading rate records						\boxtimes	
Pollution prevention plan						\boxtimes	
Pathogen/vector reduction records						\boxtimes	
Contingency Plan	\boxtimes		\boxtimes				
Spill prevention control and countermeasure (SPCC) plan	\boxtimes		\boxtimes				
Operational logs	\boxtimes		\boxtimes				
Auxiliary power check logs	\boxtimes		\boxtimes				
Notes							

Because DSRSD operates the LAVWMA Export and Storage Facilities, LAVWMA's O&M Manual, Contingency Plan, and Spill Prevention Control and Countermeasure Plan are covered under DSRSD's plans.

IV. OPERATIONS AND MAINTENANCE REVIEW

					Not
		Yes	No	N/A	Inspected
Were all records and reports required by	permit organized and				\boxtimes
available?		_	_	_	_
Was influent flow meter calibration available	able onsite?	\square			
Date of last calibration	07/10/2023				
Calibration performed by	DSRSD staff				
Was effluent flow meter calibration avail	able onsite?	\boxtimes			
Date of last calibration	07/25/2023]			
Calibration performed by	DSRSD staff				
Were flow measurement records maintain	ined for past 3 years?				\boxtimes
Is a maintenance management program i	n place?				\boxtimes
Number of open work orders	9 (corrective maintenance only)				
Oldest date of open work order	June 6, 2023	ļ			
Are entries to the operational logs made	in pen?	\boxtimes			
Were all operational log entry modification	ons made with suitable cause?	\boxtimes			
Were reported spills and bypasses record	led in operational logs?				\boxtimes
Is the facility staffing requirement describ	ped in O&M manual?				\boxtimes
Is the facility staffed in accordance with C	D&M manual?				\boxtimes
Were there auxiliary power check logs?		\boxtimes			
Air Board permit number	Not inspected				
Notes					
The oldest open work order at the Facility is a	a request to add a pressure reading o	display	on a si	urge tank	

V. MONITORING RECORDS REVIEW

					Not
		Yes	No	N/A	Inspected
Are monitoring records and la	aboratory reports retained for 5 years?	\boxtimes			
Are data reported on DMRs/S	SMRs consistent with analytical results?	\boxtimes			
Is the onsite laboratory ELAP	certified?	\boxtimes			
Certification Number	1272				
Expiration Date	8/31/2024				
					Not
				N/A	Inspected
Parameters measured onsite				N/A □	Inspected
Parameters measured onsite The DSRSD Laboratory analyzes	LAVWMA effluent. Parameters measured ons	ite can l	oe foun	N/A	Inspected
Parameters measured onsite The DSRSD Laboratory analyzes https://www.waterboards.ca.go	LAVWMA effluent. Parameters measured ons v/drinking_water/certlic/labs/documents/ela	ite can l p_certs	be foun /615.pc	N/A D d here: df	Inspected
Parameters measured onsite The DSRSD Laboratory analyzes <u>https://www.waterboards.ca.go</u>	LAVWMA effluent. Parameters measured ons v/drinking_water/certlic/labs/documents/ela	ite can l p_certs	be foun /615.pt	N/A	Inspected
Parameters measured onsite The DSRSD Laboratory analyzes <u>https://www.waterboards.ca.go</u>	LAVWMA effluent. Parameters measured ons v/drinking_water/certlic/labs/documents/ela	ite can l p_certs	oe foun /615.po	N/A	Inspected
Parameters measured onsite The DSRSD Laboratory analyzes https://www.waterboards.ca.go	LAVWMA effluent. Parameters measured ons v/drinking_water/certlic/labs/documents/ela	ite can l p_certs	pe foun /615.pd	N/A D d here: df	Inspected
Parameters measured onsite The DSRSD Laboratory analyzes <u>https://www.waterboards.ca.go</u>	LAVWMA effluent. Parameters measured ons v/drinking_water/certlic/labs/documents/ela	ite can l p_certs	pe foun /615.pc	N/A D d here: df	Inspected

Additional parameters used for internal monitoring and proces		\boxtimes	
Constituents analyzed with hand-held equipment			X
	Most recent	St	andard
	expiration date		
Monitoring and Records Review Notes			

VI. MONITORING REPORT REVIEW

				Not
	Yes	No	N/A	Inspected
Are loading calculations prepared correctly?			\times	
Are contract laboratory records and chains of custody available?	\boxtimes			
Do sampling and analytical records include:				
a. Dates, times, and locations of sampling	\boxtimes			
b. Names of individuals performing sampling				\boxtimes
c. Analytical methods	\boxtimes			
d. Results of analyses	\boxtimes			
e. Dates of analyses	\boxtimes			
f. Times of analyses, as necessary to verify holding times	\boxtimes			
g. Analysts names or initials	\boxtimes			
h. Instantaneous flow at grab sample locations, if required				\boxtimes
MONITORING PROCEDURES				
Are adequate equipment and procedures used for onsite analyses?				
рН				\boxtimes
Dissolved oxygen				\boxtimes
Temperature				\boxtimes
Turbidity				\boxtimes
UV transmittance				\boxtimes
Other				\boxtimes
Is refrigeration satisfactory?				\boxtimes
Are grab samples collected during representative discharge conditions?				\boxtimes

Do monitoring locations appear to be appropriate?	\boxtimes					
Do composite sampling procedures comply with the permit?	\boxtimes					
Are automatic samplers properly cleaned and maintained?	\boxtimes					
Are samples adequately preserved?				\boxtimes		
Are sample containers appropriate for the samples collected?				\boxtimes		
Are samples collected using appropriate protocols?				\boxtimes		
Are coliform samples collected directly into sterile containers?			\boxtimes			
Does coliform sampling occur after the last introduction of wastes?			\boxtimes			
Is the number of discharge points as described in the permit?	\boxtimes					
Are the locations of the discharge outfalls as described in the permit?	\boxtimes					
Is the name of the receiving water as described in the permit?	\boxtimes					
Is site free of any evidence of spills or bypasses?	\boxtimes					
Do the sampling and monitoring appear representative of the	\boxtimes					
Are groundwater monitoring wells canned and locked?				\square		
Notes						
Because LAVWMA's discharge is limited mostly to wet weather, composite sampling is less frequent. Therefore,						
the composite sampler was offline at the time of inspection.						

VII. FINAL EFFLUENT AND RECEIVING WATER MONITORING

Г

		Yes	No	Not Inspected
APPEARANCE OF FINAL EFFLUENT				
Condition during the inspection				
Clear (not cloudy)		\boxtimes		
Colorless		\boxtimes		
Free of sheen		\boxtimes		
Free of scum		\boxtimes		
Free of foam		\boxtimes		
Other				
Notes				
	1			1
			Upstream	Not
APPEARANCE OF RECEIVING WATER	Yes	No	is similar	Inspected
Condition during the inspection	105		is sinnar	mopeeteu
Free of distinctly visible plume				\mathbf{X}
Free of foam and sheen				\boxtimes
Free of snails				\boxtimes
Free of erosion at the discharge point				\boxtimes
Free of bottom deposits				\boxtimes

Free of filamentous algae growth					\boxtimes	
Free of microbial layers on aquatic plants					\boxtimes	
Other						
Notes						
The Facility was not discharging out of its local outfalls, so Regional Water Board staff could not observe the receiving water in San Lorenzo Creek or Alamo Canal with discharge. Regional Water Board staff also could not observe the receiving water near the deepwater outfall because the effluent flows to the Marina Dechlorination						
Facility (separate from LAVWMA's facilities), and the proceeding EBDA Common Outfall is 37,000 feet offshore.						

VIII. SITE WALK INSPECTION

Weather and site conditions present during time of inspection							
The weather was partly cloudy, and the Facility site was clean and walkable without any obstructions.							
Treatment Process	Appeared	Not	Non-	Lacking	Not		
(described in permit)	Compliant	Present	Operational	Maintenance	Inspected		
LAVWMA Export Pump Station	\boxtimes						
Equalization Basins	\boxtimes						
Notes							

Background:

LAVWMA is a Joint Powers Agency comprised of the Dublin San Ramon Services District, City of Livermore, and City of Pleasanton. The Dublin San Ramon Services District (DSRSD) operates the Export and Storage Facilities (Facility), which receives secondary-treated wastewater from the Dublin San Ramon Services District and City of Livermore wastewater treatment plants. The treated wastewater from the two treatment plants flows by gravity to the LAVWMA Export Pump Station, where the wastewater is combined and equalized in the Facility's three flow-equalization basins that together provide 18 million gallons (MG) of storage. The LAVWMA Export Pump Station pumps the combined wastewater over the Dublin Grade where it connects to the East Bay Dischargers Authority (EBDA) forcemain in San Leandro. It is then pumped to the EBDA Marina Dechlorination Facility (near the San Leandro Marina) for dechlorination and discharge through a deepwater outfall in Lower San Francisco Bay. During wet weather, LAVWMA's Wet Weather NPDES Permit allows the Facility to sometimes discharge treated effluent to San Lorenzo Creek and Alamo Canal. LAVWMA has a contract with EBDA that specifies the terms and conditions of its discharge through the EBDA system. This contract was renewed on May 19, 2021, and is in effect for 20 years.

Observations:

In September and October 2020, DSRSD inspected 28,000 feet (5.3 miles, or approximately 20 percent) of the LAVWMA pipeline via closed-circuit television. The inspection was performed by a contractor, National Plant Services, and was supervised and coordinated by DSRSD staff. The inspection revealed a structural defect flagged as severity 4, with the highest possible level being severity 5, in the proximity of a siphon. According to LAVWMA's General Manager in follow-up correspondence, DSRSD staff intend to inspect all the siphon sections in the pipeline for further defects in Spring 2024 before fixing the severity 4 structural defect and continuing to inspect the remainder of the LAVWMA pipeline.

The San Leandro Sample Station (SLSS), which is 16 miles from the DSRSD treatment plant, measures discharges to San Lorenzo Creek and is being upgraded for improved sampling and monitoring capabilities. Regional Water Board staff did not visit SLSS during this inspection.

LAVWMA discharged on March 9, 2023, to San Lorenzo Creek as part of its permitted discharge exercises to ensure that the discharge line was flushed and the discharge gate and dechlorination equipment were operational. LAVWMA discharged approximately 44,500 gallons during this exercise. The San Lorenzo Creek discharge exercise revealed an operational issue with the calcium thiosulfate pumps, which did not deliver adequate product for dechlorination, resulting in a measured residual chlorine of 0.7 mg/L. As a corrective action, DSRSD staff created a standard process to perform weekly calcium thiosulfate delivery system testing and flushing and updated the flow totalizers to provide real-time data. LAVWMA's last discharge exercise was to Alamo Canal on March 29, 2023, discharging approximately 35,000 gallons. The Facility did not encounter any issues with this second exercise.

During the inspection, the facility appeared well-kept and the LAVWMA Export Pump Station appeared in good working order, consisting of four 5 million gallon-per-day (MGD) and six 4.5 MGD pumps that provide up to 47 MGD of total pumping capacity. According to LAVWMA's General Manager, the Facility will replace Pumps 1, 3, and 5 in October 2023 because the pumps are approaching the end of their lifespan. The new pumps are expected to have improved efficiency and a longer lifespan than rebuilt pumps.

The only chemical stored onsite, calcium thiosulfate, was within a double-lined container. During the inspection, the Operations Superintendent demonstrated operating the SCADA system, which could control operations at both the DSRSD treatment plant and the Facility. A hardcopy of the Facility's Wet Weather Operation Strategy was posted next to the SCADA control station. The Facility last updated the Wet Weather Operation Strategy on December 13, 2022, and plans to review it again in November 2023.

				Not
EMERGENCY OPERATION	Yes	No	N/A	Inspected
Is available back-up power appropriate for emergency conditions?	\boxtimes			
Are there alarms systems for power and equipment failure?	\boxtimes			
Are treatment control procedures established for emergencies?	\boxtimes			

Notes

The General Manager stated there is no need for standby power for pumps because the Facility has an onsite storage capacity of 18 million gallons. In the event of a prolonged power failure, the Facility will rent a 200 kW generator that can run four pumps at a time. This generator can be obtained within 24 hours of request.

200 kW generator that can run four pumps at a time. This generator can be obtained within 24 hours of request.						
	MSDS		Secondary		Not	
	Available?		Containment?		Increated	
CHEMICALS ONSITE		No	Yes	No	Inspected	
Calcium thiosulfate			\boxtimes			
		Yes	No	N/A		
Is spill clean-up and containment equipment available?		\boxtimes				
Notes						

IX. SITE WALK OPERATION AND MAINTENANCE INSPECTION

				Not	
	Yes	No	N/A	Inspected	
Maintenance program appears to be in place and being followed	\mathbf{X}				
Lift stations appear properly maintained and have back-up power				\boxtimes	
Odors are adequately controlled, including	\times				
Ponds			X		
Headworks			\mathbf{X}		
Sludge processing facilities			X		
Storage appears to control leachate and runoff	\mathbf{X}				
Public access to storage is prevented	\mathbf{X}				
No safety concerns were observed that might interfere with proper O&M or monitoring	\boxtimes				
Flow devices appear to be property installed and maintained, and operating without interference				\boxtimes	
Notes				<u> </u>	
Stormustor bandling description					
Stormwater nandling description					

Photo Log

September 29, 2023



Figure 1. LAVWMA pump station.



Figure 2. Fully treated wastewater from the City of Livermore and DSRSD treatment plants is combined and then flows through the middle gate (Figure 3), which equalizes wastewater flows between the Facility's equalization basins.



Figure 3. Middle gate of equalization basin.



Figure 4. Calcium thiosulfate, for dechlorinating wastewater during wet weather discharges or discharge exercises, was stored within a double-lined container.



Figure 5. One of LAVWMA's two wet weather outfalls. This one discharges to Alamo Canal.